



Rural Power Company Limited  
House # 19, Road # 1/B, Sector # 9  
Uttara Model Town, Dhaka-1230  
Office of the Executive Engineer (P&C)  
www.rpcl.gov.bd



Record Number 27.26.0000.003.05.004.21.168

Date 31/7/2022

Notice

Subject: **Minutes of Pre-Tender Meeting and Clarifications of queries against Tender inquiry No: PUR-025(FG/RPP/OTM)/2021-22 Dated:30.06.2022.**

In response to the queries received from the prospective bidder(s) within the stipulated time as decided in the pre-tender meeting held on 18/07/2022, the respective clarifications from RPCL end is attached herewith.

These clarifications shall be treated as an integral part of the Tender Document.

31-07-2022

Md. Salim Bhuiyan  
Executive Director (Engineering)  
Phone: 02-48961201  
Email: edengg@rpcl.gov.bd

Copy for Kind Information and  
Necessary Action:

- 1) Managing Director, RPCL
- 2) Executive Director (Finance), Finance Department, RPCL
- 3) উপ-ব্যবস্থাপক , ICT Cell, RPCL (with request to upload the notice in to the RPCL's website)
- 4) Office copy

**Minutes of Pre-Tender Meeting and Clarifications of Queries**

Tender Name: Procurement of Spare Parts and 36K Schedule Maintenance works of Raozan 25.5MW Dual Fuel Power Plant.

Tender Ref: PUR-025(FG/RPP/OTM)/2021-22 Dated:30.06.2022

Tenderer's Name	Queries SI/No.	Pkg & Lot No.	Tender Clause/ Section	As published in Tender Notice/Document	Tenderer's Queries	Response of RPCL/ Amendment of Tender Document
A	01	Pkg-1, Lot-1	ITT Clause No. 14.1(b)	<p>The tenderer shall have specific experience of completion of at least 01 (one) No. of Contract of Similar Nature with a contract value of at least USD 1.37 (One point three seven) Million or Euro 1.31 (One point three one) Million or BDT 12.66 (Twelve Point Six Six) Crore within last three years i.e years counting backward from the date of publication of IFT in the newspaper.</p> <p>Similar Nature means: Schedule or unscheduled or Breakdown repair/maintenance of Wartsila HFO run engine, having engine capacity 8.0 MW or higher with Engine manufacturer's supplied spare parts. As a documentary evidence against specific experience, Tenderer shall have to submit an End user certificate stating that the said Plant has been in 01 (one) year continuous commercial operation after the repair or maintenance.</p> <p>This certificate shall contain at least the information of the Power Plant, Capacity of the Plant, each engine capacity, engine (Type, Make &amp; Model), work completion date, contract value, certificate issue date, name and address (telephone/fax/e-mail) of the end user duly signed in the official pad of end user.</p> <p>Tenderer must have own workshop facility or Authorization to use any standard workshop facility.</p>	<p><b>That clause may limit and make barriers for Tenderers to participate in the Tender and would reduce the competition.</b></p> <p>On the other hand, if you amend the above-mentioned ITT Clause No. 14.1(b) and consider the required experience for Manufacturer/ OEM of the Engine (i.e. Wartsila) and allow the tenderer to participate in the tender based on <u>Authorization Letter (Confirmation/Declaration about Expert Manpower Support) from Wartsila</u>, then it will make the Tender more competitive and ensure better participation.</p> <p>For your reference, here we are sharing the Tender Document of <b>BPDB</b> for an International (OTM) Tender for <i>"Procurement of Alternator L-3 Schedule Maintenance Works for all Engines, Major Overhauling Works for Compressor Unit including necessary Spare Parts, Day to Day Maintenance Expert Services by two Person along with Digital Expertise Service from OEM and Unscheduled Maintenance Works of Dohazari-Kaliaish 100MW Peaking Power Plant, BPDB, Satkania, Chattogram"</i></p> <p>In this Tender Document, here is a requirement in TDS under the ITT Clause No. 14.1(b) for <i>specific experience of the tenderer of completion of at least 01 (one) No. of Contract of Similar Nature within last five years, where Similar Nature means: Schedule or unscheduled or Breakdown repair/maintenance or Day to Day Maintenance Works or Annual Maintenance Contract of HFO run engine having capacity 8.0 MW or higher.</i></p> <p>To ensure the better competition they have provided a provision to participate in the tender by the Tenderer who does not have the Specific Experience <b>[in TDS under the</b></p>	Tender provision will prevail.







Tenderer's Name	Queries SI/No.	Pkg & Lot No.	Tender Clause/ Section	As published in Tender Notice/Document	Tenderer's Queries	Response of RPCL/ Amendment of Tender Document
					<p>ITT Clause No. 14.1(b) on Page No. 29 of the Tender Document] as follows:            "The tender who does not comply with the above-mentioned specific experience (mentioned in SL. No. iii) can participate in the tender with the authorization from Engine manufacturer for expert personnel. In this regards the tenderer must submit a declaration letter from Engine manufacturer that they will provide all necessary qualified and experienced manpower as per tender document along with the CV of the experts duly authorized by Engine Manufacturer i.e. Wartsila."            So, we are requesting your esteemed organization to amend the Tender Document as mentioned above to ensure the better competition by participation of the maximum number of Tenderer so that RPCL could purchase the Service at a best competitive price.</p>	
B	02	Pkg-1, Lot-1	GCC Clause No. 23.1 and Section 6 (B) List of Related Service and Completion Schedule	36000 Hrs schedule maintenance including L4 maintenance of Specific Engine shall be completed within 20 (Twenty) days from the date of commencement/shutdown.	36000 Hrs schedule maintenance including L4 maintenance of Specific Engine shall be completed within 30(Thirty) days from the date of commencement/shutdown.	36000 Hrs schedule maintenance of Engine including L4 maintenance of Generator shall be completed within 25 (Twenty Five) days from the date of commencement/shutdown. For 36000Hrs schedule maintenance of Engine only shall be completed within 20 (Twenty) days from the date of commencement/shutdown.
	03	Pkg-1, Lot-1	GCC Clause No. 23.2 (e)	Manufacturer's factory test certificate in one (1) original.	Manufacturer's Quality Assurance Certificate.	Manufacturer's factory test certificate in one (1) original or Quality Assurance Certificate from The Engine/Separator manufacturer in one (1) original.




  
 26/09/22  
 (Md. Saifm Bhuiyan, PEng)  
 Executive Director (Engg.)  
 Rural Power Company Limited