



Minutes of Pre-Tender Meeting and Clarifications of Queries against Tender Ref: Pur- 016(FG/GPP105MW/OTM)/2021-2022, dated: 10/03/2022.

Tenderer's Name	Queries SI/No.	Pkg & Lot No.	Tender Clause/ Section	As published in Tender Notice/Document	Tenderer's Queries	Response of RPCL/ Amendment of Tender Document
A	01	Pkg-1, Lot-1	ITT Clause ITT21.1(q), VIII	Tenderer shall have to submit at least Two nos. end user certificate (as per attached format) of completing 06 nos. Major overhauling of 17 MW or higher capacity similar type (Wartsila) diesel/HFO Engine in two different Power Plant within last 5 years stating that the tenderer has successfully completed major overhauling works (12000hrs, 24000, 36000hrs & 48000hrs etc.) of the Engine within last 5 years. And the said plant has been in continuous commercial operation. The end user certificate must contain full postal address (together with email address and fax and telephone number), so that the certificate can be verified.	Tenderer shall have to submit at least Two nos. end user certificate (as per attached format) of completing 04 nos. Major overhauling works (12000hrs, 24000,36000hrs & 48000hrs etc.) of the Engine within last 5 years. Out of 2 nos End user, One shall be Major overhauling of 17 MW or higher capacity similar type (Wartsila) diesel/HFO Engine and other One shall be Major overhauling of 8 MW or higher capacity similar type (Wartsila) diesel/HFO Engine The said plant has been in continuous commercial operation. The end user certificate must contain full postal address (together with email address and fax and telephone number), so that the certificate can be verified.	Tenderer shall have to submit end user certificate (as per attached format) of completing at least 04 nos. Major overhauling of 17 MW or higher capacity similar type (wartsila) diesel/HFO Engine within last 5 years stating that the tenderer has successfully completed major overhauling works (12000hrs, 24000,36000hrs & 48000hrs etc.) of the Engine and the said engines had been in continuous commercial operation .The end user certificate must contain full postal address (together with email address and fax and telephone number), so that the certificate can be verified.
	02		GCC Clause 23.1	12000 Hrs schedule maintenance of Specific Engine shall be completed within 18 (eighteen) days from the date of commencement/ shutdown.	12000 Hrs schedule maintenance of Specific Engine shall be completed within 25 (Twenty Five) days from the date of commencement/shutdown.	Tender provision will prevail.


 31.3.2022
 (Md. Ashraf Hossain)
 Chief Engineer (O&M)
 Rural Power Company Ltd.



 31.03.2022
 (Md. Salim Bhuiyan, PEng)
 Executive Director (Engg.)
 Rural Power Company Limited

Tenderer's Name	Queries SI/No.	Pkg & Lot No.	Tender Clause/ Section	As published in Tender Notice/Document	Tenderer's Queries	Response of RPCL/ Amendment of Tender Document
	03		GCC Clause 29.0(d)	<p>d) Import Duty, VAT, TAXES, LEVIES & Other Taxes for permanent material of the work:</p> <ul style="list-style-type: none"> The contractor will be responsible for clearing and forwarding of goods and the payment of all other charges including customs duty to be liable by the port as well as other Govt, agencies inside Bangladesh for the goods to be imported in accordance with the specifications and inland transportation (with insurance) upto plant site. RPCL shall not pay the import related duties and taxes on any replacement or any additional items. 	<p>The GCC clause 29.0, Sub clause (d) shall clearly mention that, RPCL will be responsible for the payment of import related duties, taxes, VAT, levies and all sort of charges etc. to be liable by the port as well as other Govt, agencies inside Bangladesh for the goods to be imported in accordance with the specification. But RPCL shall not pay the custom duty on any replacement/ additional items.</p>	<p>The Clause 29.0 (d) will be replaced by d) Import related duties, taxes, VAT, Levies & Other Taxes:</p> <ul style="list-style-type: none"> The contractor will be responsible for clearing and forwarding of goods to be imported in accordance with the specifications and inland transportation (with insurance) upto plant site including the payment of all other charges. RPCL will be responsible for the payment of import related duties, taxes, VAT, levies and all sorts of charges to be liable by the port as well as other Govt agencies inside Bangladesh for the goods to be imported in accordance with the specification. RPCL shall not pay the custom duty on any replacement or any additional items.
	04		GCC Clause 33.3 Warranty for Goods:	<p>The warranty period for the parts will be 24 (Twenty four) months from the date of delivery or 12 (Twelve) months from the date when the parts were placed in service whichever occurs earlier.</p>	<p>The warranty period for the parts will be 18 (Eighteen) months from the date of delivery or 12 (Twelve) months from the date when the parts were placed in service whichever occurs earlier.</p>	<p>The warranty period for the parts will be 18 (Eighteen) months from the date of delivery or 12 (Twelve) months from the date when the parts were placed in service whichever occurs earlier.</p>
	05		Section 6. Schedule of Requirements: B. List of Related Services and Completion Schedule. Final Completion Date(s) of Service for 12K	<p>12000 Hrs schedule maintenance of Specific Engine shall be completed within 12 (Twelve) days from the date of commencement/shutdown.</p>	<p>12000 Hrs schedule maintenance of Specific Engine shall be completed within 25 (Twenty Five) days from the date of commencement/shutdown.</p>	<p>12000 Hrs schedule maintenance of Specific Engine shall be completed within 18 (eighteen) days from the date of commencement/ shutdown.</p>
	06		Schedule Maintenance Service at Page number 135.	<p>The work shall be completed in 02 shifts per day.</p>	<p>Pls. delete "The work shall be completed in 02 shifts per day."</p>	<p>This line will be deleted.</p>


 31.3.2022
 Md. Ashraf Hossain
 Chief Engineer (O&M)
 Rural Power Company Ltd.

Page 2 of 2




 31/3/2022
 Md. Salim Bhuiyan, PEng
 Executive Director (Engg.)
 Rural Power Company Limited