

রুরাল পাওয়ার কোম্পানী লিমিটেড
RURAL POWER COMPANY LIMITED

Memo No: 27.26.0000.003.07.083.17. ২৩৭

Date: 12.07.2020

Subject: Amendments and Clarifications in response to the Consultants' queries against RFP reference no: PUR-008(FS/MYMENSINGH 420 MW/QCBS)/2019-20.

In response to the queries received from the shortlisted consulting firms within the stipulated time and discussion of pre-proposal meeting held on 28.06.2020, the respective amendments and clarifications from RPCL end is attached herewith. These amendments and clarifications shall be treated as an integral part of the RFP Document.

As per attached amendment, the extended deadline for submission of proposal will be 10 August, 2020 at 12:00 Hours (BST).

Thanking You.


Md. Salim Bhuiyah
12/07/2020
(Md. Salim Bhuiyah)
Executive Director (Engineering)
Contact: +8801748397594
Email: edengg@rpcl.gov.bd

Copy To:

1. Managing Director, RPCL, Dhaka
2. Executive Director (Finance), RPCL, Dhaka
3. Office Copy

Distribution To:

1. Poyry Switzerland Ltd. associated with Atlanta Enterprise Limited (AEL)
2. SMEC International Pty Ltd. in JV with ACE Consultants Ltd.
3. JV of Empresarios Agrupados Internacional S.A. and IRG Development Services Limited (IRGDSL)
4. Fichtner GmbH & Co. KG in association with Murshed Associates Limited (MAL)
5. Consortium of Tractebel Engineering Pvt. Ltd., India Power Energy Management & Engineering Company (PEMEC)
6. JV of Minconsult SDN BHD, Malaysia and Development Technical Consultants Pvt. Ltd.
7. Consortium of TUV SUD South Asia Pvt. Ltd., TUV SUD Bangladesh (Pvt.) Ltd. and MnM Power Solutions Ltd.



RURAL POWER COMPANY LIMITED

Amendments and Clarifications

FOR

REQUEST FOR PROPOSAL (RFP)

OF

**Owner's Engineer for Project Management and Construction
Supervision of Mymensingh 420 MW Dual Fuel (Gas/HSD) Combined
Cycle Power Plant Project at Mymensingh, Bangladesh**

**REF: PUR: PUR-008(FS/MYMENSINGH 420 MW/QCBS)/2019-20;
DATE:05.12.2019**

JULY - 2020

| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|---------------------------------------|-------------|--|--|--|--------------|
| 1 | ToR IV- I: Junior Mechanical Engineer | 124 | The experts should have 8 years of general experience in power sector. | <p>We are in ambiguity that you have suggested Junior Mechanical Engineer with 8 years minimum experience as Warranty Engineer. But we consider a warranty engineer must have vast experience of implementation, operation and maintenance of a Power Plant which is not possible within 8(eight) years of graduation. The warranty engineer should have notices of every happening /event in relation to the operational activities. It is usual to apprehend that the EPC contractor is suppose to envelope any happenings adverse to their interest from the notice of the client. So the warranty engineer is the eye of the client to watch every happening during operation and bring to the notice of the client (RPCL).</p> <p>Thus we consider a Senior Mechanical Engineer with vast experience in power plant implementation, operational maintenance will best suit the purpose. Thus the situation is brought to your kind notice for due addressing.</p> | <p>Job responsibility of Jr. Mechanical Engineer (Warranty period): Look after the warranty related activities described in the EPC Contract and Report RPCL Plant/Project Management accordingly.</p> | Consultant A |
| 2 | ToR IV- I: Junior Mechanical Engineer | 124 | The experts should have 8 years of general experience in power sector. | <p>We like to bring to your notice the responsibility of Junior Engineer (Warranty).</p> <ol style="list-style-type: none"> 1. Assist the Team Leader in various assignments as determined by the Team Leader. 2. Assist in the development of a comprehensive project work program and implementation schedule. 3. Ensure training of client counterpart staff through on-the-job training and classroom training programs. 4. Review, check and certify supplier's equipment system design, and assist RPCL in approving the technical documents. 5. Review methods of statement/test procedures. 6. Witnessing site inspection as per ITP commissioning guarantee and acceptance tests and issue provisional acceptance for taking over. 7. Prepare check list of materials/spares to be handed over to the client by the turnkey contractor. 8. Assist in preparing punch list (list of unfulfilled contractual obligations). 9. Assist in preparation and submission of final project completion report ; and 10. Perform other functions as may be assigned or delegated by the Team Leader from time to time during the tenure of assignment and as required by the TOR. <p>We guess a Junior Engineer is not suitable for the stipulated responsibilities. As such you may redefine the responsibilities or the post (Senior Mechanical Engineer instead of Junior Mechanical Engineer).</p> | <p>Please refer to Clarification SI No. 01.</p> | Consultant A |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|--|-------------|--|--|--|--------------|
| 3 | Section 02: Proposal Data Sheet; Junior Local Consultants: | 46 - 47 | In evaluation criteria maximum score for the Junior local Consultants - I. 20 years' experience in power sector II. 4 projects Experience in power plant. III. 4 power project implementation | For Junior Local Consultants, the consultant request to reconsider the evaluation criteria. | RFP Provision will prevail. | Consultant B |
| 4 | Section 06: III. Scope of Services; A. Project Management | 115 | The consultant will assist RPCL Project Management Unit (PMU) in preparing and implementing a PPMS to evaluate effectiveness of the project | To fulfill this requirement, it is required to have an experienced PPSM Specialist. Please confirm whether such expert need to be included. | Consultant shall provide adequate training on PPMS for at least 7 (seven) members of RPCL project management team with 3 (three) members of the consultant. Training should be for 7 (seven) days and cost of the training should be quoted in form 5B5. | Consultant B |
| 5 | Section 06: III. Scope of Services; E. Key activities of the assignment, 1. iv. | 116 | Developing and implementing a quality assurance/ control program for Monitoring schedule, inspection of materials.... | To fulfill this requirement, it is required to have an experienced Construction scheduler. Please confirm whether such expert need to be included. | EPC will cast the project schedule and the Owner's Engineer will review it. | Consultant B |
| 6 | Section 06: II. Objectives of assignment; III. Scope of Services; E. Key activities of the assignment, 1. xvi. | 117 | Assist RPCL in reviewing the detail EMP to be prepared by the contractors to ensure..... To address environmental and social impacts arising from Project execution. | To address social impacts arising from Project execution and Preparation and implementation of necessary social safeguards measures it is required to have an experienced Social Expert. Please confirm whether such expert can be included. | RFP Provision will prevail. | Consultant B |
| 7 | Section 06: III. Scope of Services; A. Project Management | 115 - 116 | Consultant shall provide adequate training on PPMS for at least 7 (seven) members of RPCL project management team Training should be for 7 (seven) days | The Consultant understand that; the PPMS training will also be included in Training and Capacity Development program, please confirm. | Confirmed. | Consultant B |
| 8 | Section 06: V. Report and document preparation | 126 | At least one (1) copy of each report should be submitted to Financing Agency and the remaining copies to RPCL. | According to ICT 3.1, the source of fund is RPCL own fund, then report should be submitted to financing agency of RPCL, Please clarify. | Amended as follows: At least one (1) copy of each report should be submitted to Financing Agency (if required) and the remaining copies to RPCL. | Consultant B |
| 9 | ITC 33.3(b), 34.1 and 36.1 | 31 | Proposal Submission Date: 26 July, 2020. | Due to this COVID-19 situation, the Consultant would like to request for the extension of Proposal Submission Date. | Amended as follows: Proposal submission date: 10 August, 2020. | Consultant B |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications / Amendments | Remarks |
|--------|---|-------------|---|---|---|--------------|
| 10 | Section 02: Proposal Data Sheet; ITC 41.2 | 31 | <p>Criteria, Sub-criteria Form 5A2</p> <p>(i) Independent consulting firm/ members of association (in case of association /joint venture) should have specific experience in consulting engineering services involving design audit and construction supervision within the last 10 years of</p> <ul style="list-style-type: none"> 1 Combined Cycle power plant capacity of 420 MW to 500 MW 1 Combined Cycle power plant capacity more than 500 MW. | <p>The Consultant requests that the criteria be eased by lowering the Combined Cycle power plant capacity to 360 MW.</p> | <p>Amended as follows:</p> <p>(i) 1.Independent consulting firm/ members of association (in case of association/joint venture) should have specific experience in consulting engineering services involving design audit and construction supervision within the last 10 years of</p> <p>1 Combined Cycle power plant capacity of 360 MW to 500MW - 6 points</p> <p>1 Combined Cycle power plant capacity more than 500MW - 9 points</p> <p>For experience of each additional power plant project having capacity of 360MW or more (Points for more than 3 projects shall not be counted) - 2 points for each project (Max. 6 points)</p> | Consultant B |
| 11 | Section 1 A. 32.4 | 18 | <p>An authorized representative of the Consultant shall initial all the pages of the Technical and Financial Proposals. The authorization shall be in the form of a written power of attorney accompanying the Proposal or in any other form demonstrating that the representative has been duly authorized to sign [...]</p> | <p>Please confirm that the Proposal could be signed by one of the member of the JV with the corresponding authorization of the other member of the JV.</p> | <p>Confirmed.</p> | Consultant C |
| 12 | Section 2 PDS. ITC 23.11 | 29 | <p>[...] Foreign Consultant shall stay in Project Site covering 80% Man-months allowed for that particular person</p> | <p>We would like to ask RCPL if it is possible to increase the percentage of the stay of the Foreign Consultant at its home offices. We consider that due to the nature of the design review activities, this works could be done from the Consultant home office where the key staff members will be supported by a multidisciplinary engineering support team of specialists in order to provide a complete revision of the Project documents. In addition, and due to the uncertainty of the current situation due to the Covid-19, it could be a good option for the foreign consultant to start the works at home office at the first phase of the project</p> | <p>Amended as follows:</p> <p>Foreign Consultant shall stay in Project Site covering 70% Man-Months allowed for that particular person. Maximum 30% of that personnel's man-month may use for Home input.</p> | Consultant C |




| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications / Amendments | Remarks |
|--------|---|-------------|---|---|------------------------------------|--------------|
| 13 | Section 3 4. Governing Law | 51 | The Contract shall be governed by and interpreted in accordance with the laws of the People's Republic of Bangladesh. | Might a neutral country be accepted? | RFP Provision will prevail. | Consultant C |
| 14 | Section 3 22.2 Modifications or Variations | 57 | Any modification or variation of the terms and conditions of the Contract, including any modification or variation of the Scope of the Services [...] | We ask to insert "and/or deadline" after "the Scope of the Services". | RFP Provision will prevail. | Consultant C |
| 15 | Section 3 34.1 Liabilities of the Consultant | 61 | Pursuant to Rule 125 (4) of the Public Procurement Rules, 2008, the Consultant, in lieu of furnishing any Performance Security, shall be, liable to and required to indemnify, the Client as stated under GCC Sub Clause 34.2 thru 34.6 inclusive for due performance of the Contract | We propose to insert at the end in article 34.1 "In any case and under any circumstances the maximum liability of the Consultant will be 75 % of the Contract Agreement Price." | RFP Provision will prevail. | Consultant C |
| 16 | Section 3 34.2 Liabilities of the Consultant | 61 | The Consultant shall indemnify the Client from and against any and all claims, liabilities, obligations, losses damages, penalties, actions, judgment, suits proceedings, demands, costs, expenses and disbursements of whatsoever nature that may be imposed on, incurred by or asserted against the Client during or in connection with the Services by reason of [...] | We suggest that the wording should be modify accordingly to indemnify both Parties. | RFP Provision will prevail. | Consultant C |
| 17 | Section 4 GCC 34.4 (b) | 80 | The ceiling on Consultant's liability shall be limited to contract value | We kindly ask to reduce to maximum 75 % | RFP Provision will prevail. | Consultant C |
| 18 | Section 4 GCC 35.1 (a) | 80 | Insurance against loss of or damage to [...] | We kindly propose to removed this sub-article. | RFP Provision will prevail. | Consultant C |
| 19 | Section 4 GCC 39.3 | 80 | "The Consultant shall not use these documents and software for purposes unrelated to this Contract without the prior written approval of the Client". | We propose to insert the following text: "A royalty free and full licence free of cost will be given to the Consultant for any Proprietary Right on Documents and Software prepared by the Consultant under this Contract." | RFP Provision will prevail. | Consultant C |
| 20 | Section 4 GCC 52.1 | 81 | Advance Payment: Not applicable | We kindly ask to include a 10 % of Advance Payment . | RFP Provision will prevail. | Consultant C |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|---|-------------|--|---|--|--------------|
| 21 | Section 6 IV. c) Electrical Engineer | 121 | Finalize all electrical system design and technical requirements with RPCL such as equipment ratings, type of equipment to be used, areas to be supplied, spares required and maintenance requirements | Please, clarify if these activities must be performed by the OE Electrical Engineer, as these activities normally are developed by the EPC company, and the OE review them. | EPC will develop and the Owner's Engineer will review them. | Consultant C |
| 22 | Section 6 IV. 2 c) Electrical Engineer | 121 | Prepare specifications for equipment and services required for the transmission and network and control system | Please, clarify if these activities must be performed by the OE Electrical Engineer, as these activities normally are developed by the EPC company, and the OE review them | EPC will develop and the Owner's Engineer will review them. | Consultant C |
| 23 | Section 6 IV. 2 d) I&C Engineer | 122 | Finalize system design and technical requirements with RPCL such as equipment ratings, type of equipment to be used, areas to be supplied spares required, and maintenance requirements | Please, clarify if these activities must be performed by the OE I&C Engineer, as these activities normally are developed by the EPC company, and the OE review them. | EPC will develop and the Owner's Engineer will review them. | Consultant C |
| 24 | Section-2, ITC 1.3, | 28 | "The assignment is to be completed within 55 Months. Project period 30 months and warranty period 25 months" | In our opinion, it should read, "The assignment is to be completed within 55 months. Project period 30 months, the warranty period of the Contractor 24 months, and Project/Service Completion Report one (1) month. Solicit Client's point of view in this respect. | Amended as follows: The assignment is to be completed within 55 months. Project period 30 months, the warranty period of the Contractor 24 months, and Project/Service Completion Report one (1) month. | Consultant D |
| 25 | Section-2, ITC 23.11, & Terms of Reference (TOR) | 29 | Mechanical Engineer (Warranty Period)- 25 Man-months | The expert position suggests that he will be stationed at the plant site from the beginning of the Warranty period until the end of the service. The task of the Expert is not well defined in the RFP. TOR says his task will be similar to those specified for International Mechanical Engineer which seems to be inappropriate, please clarify. His lodging and office facility may please be provided by the Client free of cost during his assignment at the plant site. | a) Please refer to Clarification SI No. 01. b) Only Office space will be provided for Jr. Mechanical Engineer at warranty period. | Consultant D |
| 26 | Section-2, ITC 23.11, & Section 6 - Terms of Reference (TOR) | 29 & 118 | International Consultants Man-months - contradiction | As per Section 2, page 29 of RFP states the following: Electrical Engineer – 12 man months I & C Engineer – 20 man months However as per Section 6, page 118 of RFP states the following: Electrical Engineer – 20 man months I & C Engineer – 12 man months RPCL to please confirm the correct requirement. | Correction of composition: Electrical Engineer (Foreign) – 20 man months I & C Engineer (Foreign) – 12 man months | Consultant D |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|--|-------------|--|--|---|--------------|
| 27 | Section-2, ITC 28.1(a) | 31 | The Client will provide the following services, facilities and property: Electricity and Water Supply for site office of the consultant will be provided by the client free of cost. Office space may be provided at cost. | Generally, EPC Contractor/ Client provides the furnished office for the Owner's Engineer at the site. The Client is requested to provide furnished site office for the Owner's Engineer free of cost in addition to free of cost Electricity and Water supply. | Amended as follows: Office space, Electricity and Water Supply for site office of the consultant will be provided by the client free of cost. Owner's Engineer will furnish their office in their own expense. | Consultant D |
| 28 | Section-2, Proposal Data Sheet, Clause ITC 41.2 | 31 | Criteria, Sub criteria | Bidder wishes to inform RPCL that they are presently executing the following 2 prestigious and major projects as Engineering Consultants in Bangladesh covering Design Audit & Construction Supervision: 1.Summit Meghnaghat II Power, Meghnaghat Bangladesh – 600 MW using "H" class high efficiency GE Gas turbine for the Summit Group. 2.Unique Meghnaghat Power, Meghnaghat Bangladesh – 600 MW using "H" class high efficiency GE Gas turbine for the Unique Group. RPCL may please confirm that the above projects shall be considered for award of the 15 points. | RFP Provision will prevail. Experience of ongoing projects will not be accepted. | Consultant D |
| 29 | Section-3, General Conditions of Contract, Clause 48.1 | 67 | All payments under this contractof the client country | Bidder would request RPCL to confirm that separate payments shall be made to the Consortium/Association members directly by RPCL such that: 1.Foreign Currency payments shall be paid to the International Consultant in USD (or any other FC quoted by the Bidder) directly to their overseas account through Letter of Credit 2.Local Currency payments shall be paid to the Domestic Consultant directly by Cheque in BDT. | Owner will consider. | Consultant D |
| 30 | Form 5B4: Breakdown of Remuneration | 100 | Payment of currency for Foreign Consultants "Field" staff months | RPCL to please confirm that all field months of the Foreign Consultants engineers shall be paid in Foreign Currency directly to the overseas of the Foreign Consultant through the letter of Credit. Bidder wishes to add that presently they are executing Owners Engineer assignment for Bibiyana South for BPDB and BPDB is paying all payments for the Foreign Consultant in Foreign currency. | RFP Provision will prevail. | Consultant D |
| 31 | Section -2, ITC 33.3(b), 34.1 and 36.1 | 31 | Due date for bid submission: 26 July, 2020. | Looking into the uncertain COVID 19 situation, it is requested to extend the due date for bid submission till 18 Aug 2020. | Please refer to Clarification SI No. 09. | Consultant D |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|--|-------------|--|--|--|--------------|
| 32 | PDS ITC 24.1 (j) | 30 | Specific experience certificate of the firm and personnel/expert from the client. | As far as experience certificate of personnel/expert is concerned, client usually do not issue certificate for experts. Hence, current employer would request to certify personnel's previous experiences also. | Specific experience certificate of the firm and personnel/expert from the client / employer. The declared experience without any supporting documents (Certificate) may not be considered in the evaluation. | Consultant D |
| 33 | Section 2, Proposal Data Sheet, Clause ITC 41.2 (i) Form 5A2 | 31 | (i) 1. Independent consulting firm/ members of association (in case of association/joint venture) should have specific experience in consulting engineering services involving design audit and construction supervision within the last 10 years of 1 Combined Cycle power plant capacity of 420 MW to 500MW | This Project will be based on F-Class Gas Turbine based Combined Cycle Power Plant However, for F-Class Gas Turbine based Combined Cycle Power Plant, in the last ten 10 years the capacities have increased form 310 MW (at site Conditions) to 440 MW to 480 MW currently. As such, projects executed with F-Class Gas Turbine over the last 10 years will mostly be below the minimum capacity provided in this qualification clause i. e. 420 MW. Some examples in Bangladesh are: 1. Gorashal Power Plant-416 MW (Installed Capacity) 2. Ashuganj South-382 MW (Installed Capacity) 3. Ashuganj North-389 MW (Installed Capacity) 4. Bheramara Combined Cycle Power Plant – 414 MW (Installed Capacity) 5. Ashuganj East-400 MW (approx. – under construction) Moreover, in the EOI Notice the minimum experience required is: "Consulting firm who have at least provided consulting engineering services involving design audit and construction supervision within the last ten (10) years for at least one (1) Combined Cycle Power Plant with capacity equal to or more than 200 MW" Hence, we humbly request you to amend the lower limit of the experience criteria form 420 MW to 320 MW to truly reflect the experience in F-Class Gas Turbine based Combined Cycle Power Plant. | Please refer to Clarification SI No. 10. | Consultant E |
| 34 | Section 2, Clause ITC 23.11, Table A-1 and Section 6 (ToR), Clause IV, 2 (Table 1) | 29 & 118 | Section 2, ITC 23.11: Electrical Engineer – 12 man months I & C Engineer – 20 man months Section 6 (TOR), Clause IV Table 1: Electrical Engineer – 20 man months I & C Engineer – 12 man months | Form the scope of works to be covered under the disciplines and our past experience on similar projects we feel that the provisions provided in Section 6 (TOR) are more applicable. Please Confirm. | Please refer to Clarification SI No. 26. | Consultant E |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|--|-------------|--|--|---|--------------|
| 35 | Section 2, Clause ITC 23.11, Table A-1 and Section 5, Form 5B4 (Breakdown of Remuneration) | 29 & 100 | Section 2, Clause ITC 23.11: "Foreign Consultant shall stay in Project Site covering 80% Man-months allowed for that particular person." Section 5, Form 5B4 , Note5: "...In case of Home input shall not be exceed more than 10% of total input for each individual expert." | We are of the opinion that Home input for similar combined cycle projects shall be at least 20% of the allocated man-months as stated in Section 2, Clause ITC 23.1. Please Confirm. | Amended as follows: Section 5, Form 5B4 , Note5: "...For Foreign experts 30% Home input and 70% Field input. For Local experts 100% field input." | Consultant E |
| 36 | Section 2, Clause ITC 29.1 and Section 5, Form 5B4 (Breakdown of Remuneration) | 31 & 100 | Section 2, Clause ITC 29.1: "The currency of the Proposal shall be: US Dollar, EURO, Pound and Bangladesh Taka only. Consultant to state local cost in the national currency. Yes (BDT)." Form 5B4: Columns for indicating foreign currency portion under "Field Man Months" for foreign staff is greyed out. | Please confirm that payment for Remuneration for Foreign Staff Field Man Months shall be paid in Foreign Currency i.e. US Dollar or EURO or Pound and shall be entered in Field Man Months column of Form 5B4. | RFP Provision will prevail. As Amended in clarification no. 12: Foreign Consultant shall stay in Project Site covering 70% Man-Months allowed for that particular person. Payment of field man-month will be paid in BDT. Maximum 30% of that personnel's man-month may use for Home input. Payment of Home input man-month will be paid in quoted foreign currency. | Consultant E |
| 37 | TOR i: 1 | 114 | The site is located at Geographic Position of 24045/50.50//N, 90025/20.93//E | Location of the Project Given project coordinates are in Shambhuganj, 1 km away from the river in built-up area. Are coordinates indicative or final? | As per Feasibility Study The Coordinates of the proposed power plant project sites are as follows: SI- Longitude - Latitude 1 - 90°24'59.97"E - 24°45'44.49"N 2 - 90°24'56.60"E - 24°45'47.72"N 3 - 90°24'56.88"E - 24°45'50.89"N 4 - 90°25'2.03"E - 24°45'56.11"N 5 - 90°25'5.47"E - 24°45'51.73"N 6 - 90°25'6.73"E - 24°45'52.15"N 7 - 90°25'8.39"E - 24°45'49.62"N 8 - 90°25'7.12"E - 24°45'48.90"N 9 - 90°25'6.49"E - 24°45'49.59"N | Consultant F |
| 38 | TOR III: A: 2 | 115 | Consultant should provide, establish and implement a Project Performance Monitoring System (PPMS) i.e. licensed software, which designed to assist project director and management team in developing a plan, assigning resources to tasks, tracking progress, managing the budget, and analyzing workloads. | Performance Monitoring System Is there mandatory scope for the Project Performance Monitoring System? What information and data RPCL expects? Can bidder provide own software? | RFP Provision will prevail. | Consultant F |



| SI No. | RFP Reference | Page Number | RFP Specifications | Clarifications Sought | RPCL's Clarifications /Amendments | Remarks |
|--------|---|-------------|--|--|---|--------------|
| 39 | Cl. IV c) (iv), (v) and (vi), TOR | 121 | | Scope of Electrical Engineer, Please clarify if bidder must design transmission and network control system or supply support and supervision only? | EPC will develop and the Owner's Engineer will review them. | Consultant F |
| 40 | Cl. IV d) (iii), TOR | 122 | | Scope of I&C Engineer Please clarify if bidder must design transmission and network control system or supply support and supervision only? | EPC will develop and the Owner's Engineer will review them. | Consultant F |
| 41 | Cl. IV d) (iii), TOR | 123 | | Civil Engineer The TOR considers cooling tower and water intake structure. However, the existing plant is running on air condenser. Shall the new plant have cooling tower and water intake, or air condenser and deep well to supply the treatment plant only? | There is a limitation to draw ground water for the plant water system. As such, Hybrid type cooling tower has been specified in the EPC tender document, in which less amount of makeup water will be required. The bidder based on the condition of water availability at site, shall design the plant water system accordingly. Ground water for makeup should be 125-150 m ³ /hr. | Consultant F |
| 42 | ITC 33.3(b), 34.1 and 36.1 | 31 | Proposal Submission Date: 26 July, 2020. | extension of the bid submission until August 10th 2020. | Please refer to Clarification SI No. 09. | Consultant F |
| 43 | ITC 33.3(b), 34.1 and 36.1 | 31 | Proposal Submission Date: 26 July, 2020. | we request you to kindly extend the bid submission date by 3 weeks i.e. upto 17th August 2020. | Please refer to Clarification SI No. 09. | Consultant g |
| 44 | Section-4, PCC, GCC Clause No-52.1 | 81 | Advance Payment: Not Applicable | Kindly allow provision of advance payment at-least 10% of contract value. | RFP provision will prevail. | Consultant g |
| 45 | Financial Proposal form- 5B4, & Clause no. 1 (b) & Clause no. 2 | 100 & 111 | Do not fill the shadowed field of table. Monthly rates for Foreign personal (key personnel and Other personnel: applicable when s/he work in field. Per diem expenses of foreign consultant in local currency. | We have observed that for all field related fee and expenses for Foreign consultant/ expert has been asked to quote in local currency. Looking practices of similar kind of job across global tender, we have seen this is always in foreign currency only. We request you to kindly allow to quote in foreign currency only for smooth payment realization and avoid any challenge of money transfer from Bangladesh to Foreign Consultant Country. | Please refer to Clarification SI No. 36. | Consultant g |
| 46 | General | | Page limit for CVs. | Kindly confirm, if any page limit restriction is there for CVs. | RFP provision will prevail. | Consultant g |

