

Rural Power Company Limited
House # 19, Road # 1/B
Sector # 09, Uttara, Dhaka-1230
Office of the Executive Director
(Engg.)
www.rpcl.gov.bd

"শেখ হাসিনার উদ্যোগ
ঘরে ঘরে বিদ্যুৎ"

Record Number
27.26.0000.003.06.076.14.81

Date 24/6/2019

Notice

Subject:

Minutes of Pre-Tender Meeting & Clarifications of queries against Tender inquiry No: PUR-029(FG/MPS/OTM)/2018-19, dated: 28/05/2019.

In response to the queries received from the prospective bidders and discussion of pre-tender meeting held on 16/06/2019, the respective clarifications from RPCL end and minutes of pre-tender meeting are attached herewith. These clarifications and minutes of pre-tender meeting shall be treated as an integral part of the Tender Document.



25-06-2019

Md. Salim Bhuiyan
Executive Director
(Engineering)

Phone: 02-48961201


Email: edengg@rpcl.gov.bd

CC:

- 1) Managing Director, RPCL, Dhaka.
- 2) Executive Director (F/A), RPCL, Dhaka.
- 3) Manager (ICT), RPCL, Dhaka [With a request to publish the Minutes in RPCL's Website].
- 4) Office copy.
- 5) Distribution to: a).....

Minutes of Pre-Tender Meeting & Clarifications of Queries against Tender Ref: PUR-029(FG/MPS/OTM)/2018-19 (Package-1, Lot-1), dated: 28/05/2019.

Bidder's Name	Queries SI/No.	Lot No. and Name of Lot	Clause/Section	As published in Tender Notice/Document	Bidder's Queries	Response of RPCL/Amendment of Tender Document
A	1		Total time for submission & latest date of submission.	42 days & 09/07/2019.	Bidder requested to extend total time for submission upto 31/07/2019.	Tender provision will prevail.
	2	Lot-1 (Air Filter)	TDS: ITT clause-21.1(q): SI/No-(V)	Tenderer shall have to submit the sample of the filter and the test report of offered air filter from independent European/American standard testing laboratory as per design standard of EN 779:2012/ASHRAE 52.2:2007 along with the tender. In the test report, name of the testing institute & design standard code no. should be mentioned clearly. The test of the filter should have been performed within last five years. The test report should be original or notary public certified photocopy. The sample will be examined by a committee appointed by the HOPE and must be accepted by the committee. For the sample not accepted by the committee, the offer of respective tenderer shall not be considered for further evaluation.	Tenderer requested to waive the submission of sample as they are OEM and they have supplied filters at Mymensingh Power Station several times. The Tenderer also requested to replace design standard of EN 779:2012/ ASHRAE 52.2-2007 with EN 779/ASHRAE 52.2.	Tender provision will prevail.
	3		Section 6. Schedule of Requirements	Delivery Time: 60 days on board from the date of opening letter of credit.	The Tenderer requested to extend the delivery time upto 90 days from the date of opening LC.	Tender provision will prevail.


 (Md. Saifur Rahman, PEG)
 Executive Director (Engg.)
 Rural Power Development Limited