



Rural Power Company Limited
House # 19, Road # 1/B, Sector # 9
Uttara Model Town, Dhaka-1230
Office of the Executive Director (Engineering)
www.rpcl.gov.bd

Record Number
27.26.0000.003.06.002.21.193

Date 11/10/2021

...

Subject: Circulation of Minutes of Pre-Tender Meeting and Clarifications of Queries against Tender Ref: Pur-003(FG/MPS/OTM)/2021-2022, dated: 19/09/2021.

In response to the queries received from the prospective Tenderers and discussion of pre-tender meeting held on 03/10/2021, the respective clarifications from Procuring Entity and minutes of pre-tender meeting is attached herewith. These clarifications and minutes of pre-tender meeting shall be treated as an integral part of the Tender Document.

Enclosure: Minutes of Pre-Tender Meeting and Clarifications of Queries.

13-10-2021

Md. Salim Bhuiyan
Executive Director
(Engineering)

Phone: 02-48961201

Email: edengg@rpcl.gov.bd

Cc:

- 1) Managing Director, RPCL, Dhaka.
- 2) Executive Director (F/A), RPCL, Dhaka.
- 3) Office copy.
- 4) Distribution to: a).....

Minutes of Pre-Tender Meeting and Clarifications of Queries against Tender Ref: Pur- 003(FG/MPS/OTM)/2021-2022, dated: 19/09/2021.

Tenderer's Name	Queries SI/No.	Tender Clause/ Section	As published in Tender Notice/Document	Tenderer's Queries	Response of RPCL/ Amendment of Tender Document
A	1	Section-2, ITT 21.1 (q), page - 30, D. Preparation of Tender	5. Manufacturer's Authorization Letter if the Tenderer is not manufacturer.	From the tender document we find the OEM is Standard Fasel Lentjes B.V), does it mean that the authorization is mandatory and it shall have to be from the OEM?	The original manufacturer of this equipment is Standard Fasel- Lentjes B.v. To participate in this tender, authorization from the OEM- Standard Fasel- Lentjes B.v is mandatory, if the tenderer is not manufacturer.
	2	Section-4, PCC page -52, Tools & Equipment	Supply of necessary supports, structure, frame, beam, plates etc. as required for execution of the work as per recommended design, drawings. After completion of the work those shall be handed over to RPCL.	We propose that the goods/ materials which are pre-fabricated hired/ borrowed on rental basis required for the execution of the project shall not be handed over to RPCL as they need to be returned to the owner.	Supply of necessary supports, structure, frame, beam, plates etc. as required for execution of the work as per recommended design, drawings. After completion of the work those shall be returned to the Contractor.
	3	Section-4, PCC page - 55, The following Tender document mentions that; supports may be provided by MPS, RPCL	(a) 30T Mobile crane without fuel and operator. (b) 2.5T Fork lift without fuel and operator (c) Available workshop facility at MPS (d) Office space for supervisor, executives (e) Electric Power supply 3 Phase 400V, 50Hz (f) Accommodation in MPS dorm if required (payment has to be made on pro-rata.	We request to add the following facilities for use; a) Water supply facility free of cost b) Available steel structure, sheets, beams during execution c) Temporary Shed/ store making place and permission.	RPCL will also provide the following facilities for use: i) Water supply facility free of cost. ii) Available steel structure, sheets, beams during execution. iii) Place for making temporary Shed/ store.
	4	Section-4, PCC page - 61, Factory Acceptance Test (FAT)	RPCL shall send its engineers to carry out FAT of Goods at manufacturers' workshop including transfer of technical know-how. The Contractor shall furnish all reasonable aid and assistance required by the RPCL's engineers for executing FAT of the goods. The period for this FAT will be 07 (Seven) days excluding travel time. The Contractor/ Supplier shall also bear the costs of round air tickets (Economy class), standard hotel accommodations, food, internal transportations and per diem allowances @ EUR 150.00 per person per day. Days will be counted from the date of departure to arrival in Bangladesh. The number of such personnel will be 05 (Five) for this purpose.	Generally European companies do not extend their assistance during FAT and they prefer less number of inspectors. We would propose 2-3 persons for 4/5 days excluding Travel time. Besides, we would like to request you to keep a provision for Third Party inspection by internationally reputed agent (like SGS, Lloyd's, Bureau Veritas etc.)	If the accomplishment of FAT is not possible due to Covid pandemic or any unavoidable reason, RPCL may engage an internationally reputed third party inspector to perform the FAT. The payment will be made by RPCL as well. The quoted price shall not include the cost of third party inspection.

Minutes of Pre-Tender Meeting and Clarifications of Queries against Tender Ref: Pur- 003(FG/MPS/OTM)/2021-2022, dated: 19/09/2021.

B	5	Section-2: TDS, ITT 14.1(b)	The Tenderer shall have experience of successful supply of similar goods and related services in a thermal power plant within last 12 years in a single contract of minimum 0.7M USD (Point Seven Million US Dollars) or equivalent currency.	The Tenderer shall have experience of successful supply of similar goods and related services in a Turnkey Base Project within last 12 years in a single contract of minimum 0.7M USD (Point Seven Million US Dollars) or equivalent currency.	The Tenderer shall have experience of successful supply of similar goods and related services in a power plant/ project within last 12 years in a single contract of minimum 0.7M USD (Point Seven Million US Dollars) or equivalent currency.
C	6	Section-2: TDS, ITT 14.1(b)	A Manufacturer's Authorisation Letter is required for all the items listed in Section 6: Schedule of Requirements.	We request you to amend against OEM; items/ spares to be manufactured by any experienced company including Standard fasel (The Netherland) for comparative tender bidding and giving opportunity to well experienced and renowned domestic company like us to participate in the tender.	The original manufacturer of this equipment is Standard Fasel- Lentjes B.v. To participate in this tender, authorization from the OEM- Standard Fasel- Lentjes B.v is mandatory, if the tenderer is not manufacturer.